

Pure Water Phase 2 Planning Workshop

Metro JPA

August 19, 2020

Doug Owen, Stantec

Consultant Team Manager

Pure Water Program

Roberto Yano, National City
Dexter Wilson, Dexter Wilson Engineering
Scott Tulloch, Consultant (NV5)


John Stufflebean, City of San Diego
Amer Barhoumi , City of San Diego
Lubna Arikat, City of San Diego
Victor Occiano, Brown and Caldwell
Christine Waters, CityWorks
Sean McCarty, West Coast Civil

- Review of Phase 2 Alternatives
- Alternatives Refinement Update
 - *Treatment*
 - *Conveyance*
- Next Steps

- Maximize use of assets at the PLWTP
 - *Keep wastewater treatment “centralized” at PLWTP*
- Repurpose the existing primary sedimentation basins for water reclamation plant
 - *Membrane Bioreactors*
- Straightforward expansion of secondary treatment if waiver is lost and no secondary equivalency
- Reduce the amount of facilities constructed on “new” parcels
 - *Stadium site was uncertain with potential SDSU West development*

Alternative Development includes combinations of:

- Water Reclamation Plant
 - Point Loma
 - Harbor Drive
- Purified Water Facility
 - Harbor Drive
 - Mission Valley
- With and Without Waiver/Secondary Equivalency
- Brine/Centrates bypass of PLWTP directly to ocean outfall
- Padre Dam 11.5 mgd ECAWP facility a part of a “regional” 83 mgd solution





Summary of Alternatives

Alt	Secondary Equiv	Brine/Treated Centrate Bypass	Regional Purified Water Production	CAWRP/CAPWF Combined at Harbor Dr	Phase 2 Pure Water Production (mgd)
1A	X				53
1B					53
1C	X	X			53
1D		X			53
1E	X		X		41.5
1F		X	X		41.5
1G	X		X	X	41.5
1H		X	X	X	41.5
3A	X	X			53
3B		X			53
3C	X	X	X		41.5
3D		X	X		41.5



Summary of Alternatives

Alt	Secondary Equiv	Brine/Treated Centrate Bypass	Regional Purified Water Production	CAWRP/CAPWF Combined at Harbor Dr	Phase 2 Pure Water Production (mgd)
1A	X				53
1B					53
1C	X	X			53
1D		X			53
1E	X		X		41.5
1F		X	X		41.5
1G	X		X	X	41.5
1H		X	X	X	41.5
3A	X	X			53
3B		X			53
3C	X	X	X		41.5
3D		X	X		41.5



Summary of Alternatives

Alt	Secondary Equiv	Brine/Treated Centrate Bypass	Regional Purified Water Production	CAWRP/CAPWF Combined at Harbor Dr	Phase 2 Pure Water Production (mgd)
1A	X				53
1B					53
1C	X	X			53
1D		X			53
1E	X		X		41.5
1F		X	X		41.5
1G	X		X	X	41.5
1H		X	X	X	41.5
3A	X	X			53
3B		X			53
3C	X	X	X		41.5
3D		X	X		41.5



Summary of Alternatives

Alt	Secondary Equiv	Brine/Treated Centrate Bypass	Regional Purified Water Production	CAWRP/CAPWF Combined at Harbor Dr	Phase 2 Pure Water Production (mgd)
1A	X				53
1B					53
1C	X	X			53
1D		X			53
1E	X		X		41.5
1F		X	X		41.5
1G	X		X	X	41.5
1H		X	X	X	41.5
3A	X	X			53
3B		X			53
3C	X	X	X		41.5
3D		X	X		41.5

- Centrate significantly impacts water reclamation plant sizing and treatability
 - *Bypass brine/centrate around water reclamation plant*
 - *For Alternative 3, centrate must be treated for ocean discharge*
- Existing primary sedimentation basins at PLWTP cannot be retrofitted for secondary treatment
 - *Insufficient volume, too shallow, and can't accommodate membrane bioreactors*
 - *For Alternative 3, different processes for water reclamation plant and secondary conversion (loss of waiver)*
- The City has secured the Mission Valley site


Treatment Layouts



Treatment Elements

- Discharge to Murray Reservoir
 - *Direct Potable Reuse – Raw Water Augmentation*
- Water Reclamation Plant
 - *Enhanced primary treatment*
 - *Chemically-enhanced primary treatment or Densadeg®*
 - *Biological nutrient removal*
 - *Membrane Bioreactors*
- Purified Water Facility
 - *Ozone/biologically active carbon*
 - *Membrane filtration*
 - *Reverse Osmosis*
 - *Ultraviolet/Advanced Oxidation Process*
 - *Pipeline chlorination*


- Treatment options for:
 - *Primary Treatment*
 - CEPT (as shown)
 - DensaDeg
 - *CAWRP Secondary/Tertiary Treatment*
 - **BNR/Secondary Clarifiers/Tertiary Filters** (insufficient land)
 - **Fine Screens/BNR/MBR** (as shown)



Alt	Influent AADF (mgd)
1A, 1B	69

- Treatment options for:
 - *Primary Treatment*
 - CEPT (as shown)
 - DensaDeg
 - *CAWRP Secondary/Tertiary Treatment*
 - **BNR/Secondary Clarifiers/Tertiary Filters** (insufficient land)
 - **Fine Screens**/BNR/MBR (as shown)

Alt	CAWRP Influent AADF (mgd)
1A - 1B	69
1E	53




SD Alternative 1 (53 mgd) – Mission Valley CAPWF Site Plan

■ Treatment processes include:

- *Ozone*
- *BAC*
- *MF*
- *RO*
- *UV/AOP*
- *Post Treatment*

Alt	CAPWF Influent (mgd)
1A-1D	66




Full Secondary Treatment at Point Loma

Discharge Limits – Secondary Effluent Standards

Parameter	30-d Average (Average Monthly) ^a	7-d Average (Average Weekly) ^b
BOD ₅	30 mg/L (or 25 mg/L CBOD ₅)	45 mg/L (or 40 mg/L CBOD ₅)
TSS	30 mg/L	45 mg/L
pH	Within the limits of 6.0-9.0	
BOD ₅ and TSS removal (concentration)	≥ 85%	
a Calendar Month in accordance with 40 CFR 122, Section 122.45(d)(2) b Calendar Week in accordance with 40 CFR 122, Section 122.45(d)(2)		

Exhibit 5-2 in Chapter 5 of the NPDES Permit Writer's Manual (2010)

Biological Aerated Filter Configuration at PLWTP




SD Alternative 1 – PLWTP Site Plan (Full Secondary)

■ Treatment options for:

- *PLWTP Primary Treatment*
 - CEPT (evaluating)
 - DensaDeg (as shown)
- *PLWTP Secondary Treatment*
 - Fine Screens/BAF
- *Sludge Thickeners*
 - Gravity Thickeners


Alt	PLWTP Influent/Effluent (mgd)		CAWRP Combined Sludge Flow (mgd)
	AADF	PWWF	
1B	78/76	285/279	3.2 - 4.9



SD Alternative 3 – PLWTP Site Plan (Full Secondary)

- Treatment options for:
 - *PLWWTP & CAWRP Primary Treatment*
 - CEPT (insufficient land)
 - DensaDeg (as shown)
 - *PLWWTP Secondary Treatment*
 - Fine Screens/BAF (as shown)
 - *CAWRP Secondary/Tertiary Treatment*
 - BNR/Secondary Clarifiers/Tertiary Filters (insufficient land)
 - Fine Screens/BNR/MBR (as shown)
 - *Sludge Thickeners*
 - Gravity Thickeners

Alt	PLWTP Influent PWWF (mgd)	CAWRP Influent AADF (mgd)
3B	327	70



SD Alternative 3 – PLWTP Site Plan (Full Secondary)

- Treatment options for:
 - *PLWWTP & CAWRP Primary Treatment*
 - CEPT (insufficient land)
 - DensaDeg (as shown)
 - *PLWWTP Secondary Treatment*
 - Fine Screens/BAF (as shown)
 - *CAWRP Secondary/Tertiary Treatment*
 - BNR/Secondary Clarifiers/Tertiary Filters (insufficient land)
 - Fine Screens/BNR/MBR (as shown)
 - *Sludge Thickeners*
 - Gravity Thickeners


Alt	PLWTP Influent PWWF (mgd)	CAWRP Influent AADF (mgd)
3B	327	70
3D	327	55




■ Treatment processes include:

- *Ozone*
- *BAC*
- *MF*
- *RO*
- *UV/AOP*
- *Post Treatment*

Alt	CAPWF Influent (mgd)
3A, 3B	66
3C, 3D	52



Conveyance Options






- 6 Routes analyzed
- 2 Bay options
- 2 Navy Channel crossing locations
- New tunnel location vs. existing tunnel location



Conveyance Evaluation Criteria

- Health and Safety
- Community Impact
- Environmental Impact
- Property and Easements
- System Complexity
- System Efficiency
- Operational Reliability and Flexibility
- Ability to Implement

Cost



Note: Alignments are not final and will be further evaluated under future Phase 2 planning.
Only for purposes of determining potential costs.



Conceptual Phase 2 Schedule Milestones

Milestone	Phase 2
Phase 2 refinement of alternatives	January 2020 – March 2021
City recommends alternative for Phase 2	March 2021 – June 2021
Demonstration testing	February 2020 (planning) - 2026
10% Design	October 2024 – July 2025
Environmental Permitting	July 2025 – February 2030
30% Design	August 2026 – May 2027
Final Design	2027 - 2029
Construction	2029 – 2034 ⁽¹⁾

1. 2035 deadline for Pure Water production

- Finalize Alternatives Definition
- Prepare Cost Estimates
- Populate and Assess Evaluation Matrix
- Prepare Technical Memorandum

